

# Government College of Engineering

## Station Road, Osmanpura, Aurangabad – 431 005

Phone : (0240) 2366101, 110, 111  
E-Mail – [principalgeca@yahoo.com](mailto:principalgeca@yahoo.com)

Fax : (0240) 2332835  
Web – <http://www.geca.ac.in>

No. GECA/Workshop/ Store/2018/ 3322

Date 4 OCT 2018

- 01) Office Notice Board.
- 02) Institute web site.
- 03) Office Copy

Subject :- Quotation for Purchase Of Split Air Conditioner 1Ton Cap.

Dear Sir,

You are requested to send your competitive quotations for the supply of the following items subject to the following conditions.

### CONDITIONS:


- 1 Rates quoted should be FOR AURANGABAD or free delivery at the Institute inclusive of all lead and Lift.
- 2 Detailed specifications of the articles you intend to supply should be given. If not according to the specification, laid down here under.
- 3.The material should be supplied within ( 01) Week from the date of order. List of material is given below.
- 4.The earliest delivery period should be quoted if you cannot supply within the period mentioned above.
- 5.Quotation should be in sealed cover and superscripted as “Quotations” for Split Air Conditioner 1Ton Cap Due on : 11/10/18, at 5 P.M.
- 6.Quotation should be valid for six month.
- 7.Right to reject any or all quotations rights are with the under signed.
- 8.Rates quoted must be inclusive of All applicable Taxes.
9. Installation & Demonstration of the machines/equipments will be carried out free of cost at our institute by the supplier
10. No advance shall be paid and No part payment shall be made.
- 11.Quotation not complying with the above conditions and incomplete once will not be considered.
12. The supplier has to provide a warrenty certificate for 3 years without charge , against manufactureing defects. To undertake repair & replacement if any.

Sr. No.	Descriptions	Qty.
01	<b>Split Air Conditioner 1Ton Cap :-</b>	
	Cooling Capacity	1 Ton
	Air Circulation (cu ft / hr)	550
	Noise Level (db) indoor unit (Cooling Unit)	Less than 30 db at (minimum Speed)
	Average Electrical Power	Less than 1.6 KW with tolerance of 10%
Warranty Period	One Year on complete unit & after completion of one year four years on compressor.	
	01) Eco friendly gas R410a or equivalent should be used as a refrigerant. The refrigent gas should not have any action in Ozone layer depletion. 02) The Eco friendly inverter type wall mounted split air conditioner should be energy efficient. 03) Department will not provide any wire or cable for the installation of same. The out door & indoor units power supply cable should be provided with single length cable , as no joints are permitted. 04) Only copper material condenser units & cooling unit will be accepted. 05) Minimum 4.00 mtrs. Copper tubes along with each unit must be supplied. 06) In order to cover the blank area , as per site requirement supplier should provide glasses (5mm) & sun films , MS grills or Aluminum grills in place of	

- old air conditioners.
- 07) Suply , Installation , commissioning & testing of split Ac using proper tools & procedures.
- 08) Refinishing / closing of all holes / penetrations, done for the installation of the Ac by the supplier using his materials , manpower & tools. Supply of O & M manual.
- 09) One year onsite servicing & guarantee after installation.
- 10) Only original equipment manufacturers & their authorized dealers /distributor/representatives are eligible for submitting abid against this quotation.
- 10) Delivery , packing & Transportation proper packing & safe delivery within 05 days from the date issu of order of Ac at Govt. College of Engineering, Aurangabad.is the responsibility of vendor only.
- 11) Guarantee Period minimum of 12 months.

Sr. No.	Parameter	Unit	Value
01	Preferred Makes		Blue star, Daikin, Hitachi, LG, Voltas, Samsung, Mitsubishi, Toshiba.
02	Tonnage	Ton	1 (One)
03	Star Rating	Stars	4 or above
04	Rated EER	W/W	3.0
05	Power Supply	V/Hz/Ph	230/50/1 phase
06	Air Flow Volume - Indoor	CMH	1100 or equivalent
07	Compressor Warranty		05 Years

Yours faithfully

  
Principal  
Govt. College of Engineering  
Aurangabad.